

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Our water system recently violated drinking water standards. Although this was not an emergency, as our customers, you have a right to know what happened, what you should do, and what we are doing to correct this situation.

Delaware Co. RWD #7 Has Levels of Haloacetic Acids (HAA5) Above Drinking Water Standards

We routinely monitor for the presence of drinking water contaminants. Testing results we received for indicated time period(s) show that our system exceeds the standard, or maximum contaminant level (MCL), for haloacetic acids. The standard or MCL for haloacetic acids is 0.060 mg/l. It is determined by averaging all the samples collected at each sampling location for the past 12 months. The level of haloacetic acids averaged at our system's locations was the following:

Monitoring Location	Twelve-month time period	Locational RAA
DBPMX- 69700 E 280 Rd	Fourth Quarter 2024	0.072 mg/L

What should I do? There is nothing you need to do unless you have a severely compromised immune system, have an infant or are elderly. These people may be at increased risk and should seek advice about drinking water from their health care providers.

What does this mean? This is not an emergency. If it had been, you would have been notified immediately.

Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

CORRECTIVE ACTION

What happened? What is being done? When will the violation be resolved?

Failed Average for the year
Flushing more water to resolve the issue

For further information contact: Chad Lacrone System Operator

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by Delaware Co. RWD #7 PWSID#: OK3002138 NOV #: P-3002138-25-1

Date Distributed: 2/25/25